# Greater Noida Industrial Development Authority

Plot No.–01, Sector- K.P.-4, Greater Noida City, District-Gautam Budh Nagar (U.P.)
website: www.greaternoidaauthority.in email id: authority@gnida.in

**Letter Ref. No. : JAL/2026/** 958 **Date :** 13/08/26

## SAFE DRINKING WATER CERTIFICATE

It is certified that drinking water as per test report (attached) from ITS Testing Laboratory Pvt. Ltd., Noida in premises of **The Modern Scholar International School, Plot No HS-58/1, Sector K.P.-05, Greater Noida West** was Submitted by Principal of The Modern Scholar International School found satisfactory. You are requested to ensure to above the condition throughout the norms by the Central/State/UP Govt.

This certificate is valid for one year from date of issue.

13/8/26

Senior Manager (JAL)

राजीव कुमार
वरिष्ठ प्रबन्धक (सिविल)
ग्रे० नो० औ० वि० प्रा०

To,

**The Principal**
The Modern Scholar International School,
Plot No HS-58/1, Sector K.P.-05
Greater Noida West
G.B. Nagar (U.P.)

# ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181




## TEST REPORT

### Water Sample Analysis

**Report Code: W-100726-47** **Issue Date: 14/07/2026**

**Issued To:** **M/S. THE MODERN SCHOLAR INTERNATIONAL SCHOOL**
**Plot No. HS-58/1, Sector-K.P.-5, Greater Noida (west), U.P.**

**SAMPLING & ANALYSIS DATA**

| | | |
|---|---|---|
| **Sample Description** | : | **Drinking Water Sample** |
| **Source of water** | : | **RO. Water** |
| **Sample Drawn On** | : | 10/07/2026 |
| **Sample Drawn By** | : | Mr. K.K Sharma (ITS LAB Representative) |
| **Sampling Plan &Procedure** | : | IS:17614 (Part-1):2021 |
| **Sample Quantity** | : | 2.0 Liter in Pet Bottle & 200 ml Glass Sterilized Bottle |
| **Weather Condition** | : | Clear |
| **Sample Received On** | : | 10/07/2026 |
| **Analysis Duration** | : | 10/07/2026 To 14/07/2026 |
| **Standard Limits** | : | As per IS: 10500:2012 Drinking water second Revision on dated 01:05:2015 |

**ANALYSIS TEST RESULTS**

**Chemical Analysis**

| S. No. | Parameter | Test Method | Results | Requirement (Acceptable Limit) | Permissible Limit in absence of alternate source |
|---|---|---|---|---|---|
| 1. | pH Value @ 25$^0$C | IS:3025 (Part-11) | 6.94 | 6.5 – 8.5 | - |
| 2. | Colour (Hazen) | IS:3025 (Part-04) | <5.0 | 5 | 15 |
| 3. | Odour | IS:3025 (Part-05) | Agreeable | Agreeable | Agreeable |
| 4. | Taste | IS:3025 (Part-08) | Agreeable | Agreeable | - |
| 5. | Turbidity (NTU) | IS:3025 (Part-10) | <1.0 | 1 | 5 |
| 6. | Total Hardness (as CaCO3) (mg/l) | IS:3025 (Part-21) | 36.0 | 200 | 600 |
| 7. | Chloride(as Cl) (mg/l) | IS:3025 (Part-32) | 30.0 | 250 | 1000 |
| 8. | Calcium (as Ca) (mg/l) | IS:3025 (Part-40) | 7.2 | 75 | 200 |
| 9. | Total Iron (as Fe) (mg/l) | IS:3025 (Part-53) | <0.05 | 1.0 | - |
| 10. | Nitrate (as $NO_3$) | IS:3025 (Part-34) | <0.1 | 45 | No Relaxation |
| 11. | Total Dissolved Solid (TDS) (mg/l) | IS:3025 (Part-16) | 132 | 500 | 2000 |
| 12. | Alkalinity (as $CaCO_3$) (mg/l) | IS:3025 (Part-23) | 28.0 | 200 | 600 |
| 13. | Fluoride (as F) (mg/l) | IS:3025 (Part-60) | <0.1 | 1.0 | 1.5 |
| 14. | Sulphate (as $SO_4$) (mg/l) | IS:3025 (Part-24) | <1.0 | 200 | 400 |
| 15. | Magnesium (as Mg) (mg/l) | IS:3025 (Part-46) | 4.37 | 30 | 100 |

**Microbiological Analysis**

| RESULTS | | | | |
|---|---|---|---|---|
| S.No. | Parameter | Test Method | Results | Limits |
| 1. | Escherichia coli, (cfu/100ml) | IS-15185:2016 | Absent | Absent/100 ml |
| 2. | Coliform Bacteria, (cfu/100ml) | IS-15185:2016 | Absent | Absent/100 ml |

**Remarks:** Based on above tested parameter, Water sample meets as per IS-10500:2012 in specification.

**Note:** - Report shall not be produce except in full without approval of the laboratory.

Reviewed by

***End of Report***

Authorized Signatory

ITS TESTING LABORATORY PVT. LTD.

*Terms & Conditions :*

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability or our laboratory is limited to invoiced amount.

**GREATER NOIDA INDUSTRIAL DEVELOPMENT AUTHORITY**
Plot No.-01, Sector- Knowledge Park.- 4, Greater Noida
Distt.- G.B. Nagar (U.P.)- 201310

Reff.: H.D./2026/1479 Date :29 /07/2026

## SANITARY CONDITION CERTIFICATE.

It is certified that an inspection team headed by **Senior Manager (Health)** from **Greater Noida Industrial Development Authority, Plot No.-01, Sector Knowledge Park-IV, Greater Noida-201310** PHED inspected the Greater Noida Industrial Development Authority inspected **The Modern Scholar International School, Add.: Plot No–HS 58/1, Sector KP-5, Greater Noida, Distt.- G.B. Nagar (UP)** maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.P. Govt.

This Certificate is valid till for One Year.

Signature with Seal: ..... 29/07/26
Name: **Rajesh Kumar**
Designation : Senior Manager (Health)
Name & Address of the Office / Department :
**Greater Noida Industrial Development Authority,**
**Plot No.-01, Sector Knowledge Park-IV, Greater Noida**

To,

The Principal
The Modern Scholar International School,
Add.: Plot No–HS 58/1, Sector KP-5, Greater Noida,
Distt- G.B. Nagar (U.P.)