Greater Noida Industrial Development Authority

Plot No.–01, Sector- K.P.-4, Greater Noida City, District-Gautam Budh Nagar (U.P.)
website: www.greaternoidaauthority.in email id: authority@gnida.in

Letter Ref. No. : JAL/2026/ 958 **Date :** 13/08/26

SAFE DRINKING WATER CERTIFICATE

It is certified that drinking water as per test report (attached) from ITS Testing Laboratory Pvt. Ltd., Noida in premises of **The Modern Scholar International School, Plot No HS-58/1, Sector K.P.-05, Greater Noida West** was Submitted by Principal of The Modern Scholar International School found satisfactory. You are requested to ensure to above the condition throughout the norms by the Central/State/UP Govt.

This certificate is valid for one year from date of issue.

13/8/26

Senior Manager (JAL)
वरिष्ठ प्रबन्धक (जिवित)
ग्रे० नो० औ० वि० प्रा०

To,

The Principal
The Modern Scholar International School,
Plot No HS-58/1, Sector K.P.-05
Greater Noida West
G.B. Nagar (U.P.)

Principal

Chairman
Sharda Foundation
58/1, Knowledge Park
Greater Noida (U.P.)

ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itirclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764

TC-11181

TEST REPORT

Water Sample Analysis

Report Code: W-100726-47 **Issue Date: 14/07/2026**

Issued To: **M/S. THE MODERN SCHOLAR INTERNATIONAL SCHOOL**
Plot No. HS-58/1, Sector-K.P.-5, Greater Noida (west), U.P.

SAMPLING & ANALYSIS DATA

Sample Description	:	**Drinking Water Sample**
Source of water	:	**RO. Water**
Sample Drawn On	:	10/07/2026
Sample Drawn By	:	Mr. K.K Sharma (ITS LAB Representative)
Sampling Plan &Procedure	:	IS:17614 (Part-1):2021
Sample Quantity	:	2.0 Liter in Pet Bottle & 200 ml Glass Sterilized Bottle
Weather Condition	:	Clear
Sample Received On	:	10/07/2026
Analysis Duration	:	10/07/2026 To 14/07/2026
Standard Limits	:	As per IS: 10500:2012 Drinking water second Revision on dated 01:05:2015

ANALYSIS TEST RESULTS

Chemical Analysis

S. No.	Parameter	Test Method	Results	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	pH Value @ 25°C	IS:3025 (Part-11)	6.94	6.5 – 8.5	-
2.	Colour (Hazen)	IS:3025 (Part-04)	<5.0	5	15
3.	Odour	IS:3025 (Part-05)	Agreeable	Agreeable	Agreeable
4.	Taste	IS 3025 (Part-08)	Agreeable	Agreeable	-
5.	Turbidity (NTU)	IS 3025 (Part-10)	<1.0	1	5
6.	Total Hardness (as CaCO3) (mg/l)	IS:3025 (Part-21)	36.0	200	600
7.	Chloride(as Cl) (mg/l)	IS:3025 (Part-32)	30.0	250	1000
8.	Calcium (as Ca) (mg/l)	IS:3025 (Part-40)	7.2	75	200
9.	Total Iron (as Fe) (mg/l)	IS:3025 (Part-53)	<0.05	1.0	-
10.	Nitrate (as NO_3)	IS:3025 (Part-34)	<0.1	45	No Relaxation
11.	Total Dissolved Solid (TDS) (mg/l)	IS:3025 (Part-16)	132	500	2000
12.	Alkalinity (as $CaCO_3$) (mg/l)	IS:3025 (Part-23)	28.0	200	600
13.	Fluoride (as F) (mg/l)	IS:3025 (Part-60)	<0.1	1.0	1.5
14.	Sulphate (as SO_4) (mg/l)	IS:3025 (Part-24)	<1.0	200	400
15	Magnesium (as Mg) (mg/l)	IS:3025 (Part-46)	4.37	30	100

Microbiological Analysis

RESULTS

S.No.	Parameter	Test Method	Results	Limits
1.	Escherichia coli, (cfu/100ml)	IS-15185:2016	Absent	Absent/100 ml
2.	Coliform Bacteria, (cfu/100ml)	IS-15185:2016	Absent	Absent/100 ml

Remarks: Based on above tested parameter, Water sample meets as per IS-10500:2012 in specification.
Note: - Report shall not be produce except in full without approval of the laboratory.

Reviewed by

End of Report

Authorized Signatory

ITS TESTING LABORATORY PVT. LTD.

Terms & Conditions :
1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.

GREATER NOIDA INDUSTRIAL DEVELOPMENT AUTHORITY
Plot No.-01, Sector- Knowledge Park.- 4, Greater Noida
Distt.- G.B. Nagar (U.P.)- 201310

Reff.: H.D./2026/1479 Date :29/07/2026

SANITARY CONDITION CERTIFICATE.

It is certified that an inspection team headed by **Senior Manager (Health)** from **Greater Noida Industrial Development Authority, Plot No.-01, Sector Knowledge Park-IV, Greater Noida-201310** PHED inspected the Greater Noida Industrial Development Authority inspected **The Modern Scholar International School, Add.: Plot No–HS 58/1, Sector KP-5, Greater Noida, Distt.- G.B. Nagar (UP)** maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.P. Govt.

This Certificate is valid till for One Year.

Signature with Seal: 29/07/26
Name: **Rajesh Kumar**
Designation : Senior Manager (Health)
Name & Address of the Office / Department :
Greater Noida Industrial Development Authority,
Plot No.-01, Sector Knowledge Park-IV, Greater Noida

To,

The Principal
The Modern Scholar International School,
Add.: Plot No–HS 58/1, Sector KP-5, Greater Noida,
Distt- G.B. Nagar (U.P.)

Shivani Tyagi
Principal

Chairman
Sharda Foundation
58/1, Knowledge Park-5,
Greater Noida (U.P.)